

Component Description

Retrofit Kit for Inert Selector Valve with Placement Monitor P/N 85-220000-002

Effective: November 2015
K-85-3007 Rev AA

FEATURES

- *UL Listed, ULC Listed, and FM Approved for use with systems listed below in the Compatibility table.*



CONTENTS

- Upper Bracket
- Lower Bracket
- Switch (NEMA 4 rated)
- Solenoid
- Fastening Hardware
- Conduit Connector

COMPATIBILITY

Series	DIOM P/N	Supplement P/N
Kidde Nitrogen	06-237459-001	06-237459-002
Kidde Argonite	06-236432-001	06-236432-002

ORDER INFORMATION

Part Number	Description
85-220000-002	Retrofit Kit for Solenoid Placement Monitor - Selector Valve, includes switch and accessories

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly. If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL, Inc.

Kidde is a registered trademark of Kidde-Fenwal Inc. All other trademarks are the property of their respective owners.